## **UEB334 Series**



Low Cost, Dynamic Vibration IEPE Ultrasound Sensor, 1/4-28 Mounting, Top Exit 2 Pin Mini-MIL Connector, 100 mV/g, ±15%






## High Frequency Ultrasound Accelerometer

- High Amplitude Resonance Peak for Stress
  Wave Measurement Techniques
- ► IEPE Amplifier Technology
- Suggested Magnetic Mounting Bases:
  MHT8at-SAurface Magnet or MH137-1A Curved
  Surface Magnet





Specifications	Standard		Metric	Specifications	Standard		Metric
Part Number	UEB334		M/ or M8/UEB334	<u>Environmental</u>			
Sensitivity (±15%)		100 mV/g		Operating Temperature Range	-58 to 250 °F		-50 to 121 °C
Frequency Response (±3dB)	30-1,380,000 CPM		0.5 Hz-23 kHz	Maximum Shock Protection		10,000g, peak	
Frequency Response (±10%)	60-600,000 CPM		1 Hz-10 kHz	Electromagnetic Sensitivity		CE	
Dynamic Range	*	± 80g, peak Vsource ≥ 22V, 12Vbias		Sealing		Welded, Hermetic	
Peak Sensitivity		+21 dB ± 2 dB		SIL Rating		SIL 2	
<u>lectrical</u>				<u>Physical</u>			
Settling Time		< 2 Seconds		Sensing Element		PZT Ceramic	
Voltage Source (IEPE)		18-30 VDC		Sensing Structure		Shear Mode	
Constant Current Excitation		2-10 mA		Weight	0.7 oz		20 g
Spectral Noise @ 10 Hz		30 μg/√Hz		Case Material		316L Stainless	
Spectral Noise @ 100 Hz		4 μg/√Hz		Case Material		Steel	
Spectral Noise @ 1000 Hz		2 μg/√Hz		Mounting Thread		1/4-28 UNF	
Output Impedance		< 100 ohm				2 Pin mini-MIL,	
Bias Output Voltage		10-14 VDC		Connector (Non-Integral)		J Series	
Case Isolation		> 10 <sup>8</sup> ohm				Connector	
				Resonant Frequency	2,520,000 CPM ±12,000 CPM		42 kHz ±2kHz
				Mounting Torque	2 to 5 ft. lbs.		2,7 to 6,8 Nm
				Mounting Hardware Supplied	1/4-28 Stud		M6x1 or M8x1.2 Adapter Stud
				Calibration Certificate		CA10	

Typical Frequency Response

